

**APPENDIX-VIII**

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE**

No. 931

Date: 31/05/22

It is certified that an inspection team headed by Rajesh Kumar Chemist (Name of Officers with designation) from Public Health Division, Bihar Sharif (Name of Department/Office) inspected the Vidya Jyoti school, Bhatu Bigha Ekangar Sarai, Nalada (Name & Address of the School) on 30/05/2022 and found that the Vidya Jyoti school, Bhatu Bigha Ekangar Sarai, Nalada (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of six months.

Signature with Seal: \_\_\_\_\_

*Rama Shankar Singh*  
31.5.22

Name - Rama Shankar Singh

Designation - Executive Engineer

Public Health Division, Bihar Sharif

Executive Engineer  
P.H. Division, Bihar Sharif

To

Principal

Vidya Joyti School , Bhatu Bigtha

Ekangar Sarai, Nalanda

(Name & Address of the Institution)

**Government of Bihar**  
**Public Health Engineering Department**  
**Water Quality Report**

District Name: Nalanda

Sample Collected by : - School Staff

Sample Collection date : - 28/05/2022

Format: I

| Sl. No.   | Block        | Panchayat   | Village     | Name of Habitation | Ward No, | Location of Source | Test result |       |     |      |     |     |     |      |       |      |                 |                 |      |        | Source of Water |
|---|--------------|-------------|-------------|--------------------|----------|--------------------|-------------|-------|-----|------|-----|-----|-----|------|-------|------|-----------------|-----------------|------|--------|-----------------|
|   |              |             |             |                    |          |                    | pH          | Turb. | EC  | TDS  | TH  | Ca  | Mg  | Cl   | Alka. | Fe   | NO <sub>3</sub> | SO <sub>4</sub> | F    | T.Coil |                 |
| 1   | 2            | 3           | 4           | 5                  | 6        | 7                  | 8           | 9     | 10  | 11   | 12  | 13  | 14  | 15   | 16    | 17   | 18              | 19              | 20   | 21     | 22              |
| 1   | Ekangersarai | Ekanger Dih | Bhatu Bigha | Bhatu Bigha        | 13       | Vidya Jyoti School | 7.54        | 0.65  | 810 | 550  | 260 | 56  | 20  | 50   | 280   | 0.11 | 0.41            | 9.6             | 0.41 | <1.1   | Tubewell        |
| Desirable Limit*                                  |              |             |             |                    |          |                    | 6.5-8.5     | 1.0   | -   | 500  | 200 | 75  | 30  | 250  | 200   | 0.3  | 45              | 200             | 1.0  | -      | -               |
| Permissible Limit* in absence of alternate source |              |             |             |                    |          |                    | NR          | 5.0   | -   | 2000 | 600 | 200 | 100 | 1000 | 600   | NR   | NR              | 400             | 1.5  | **     | -               |

Remarks :-

*Pragathi Kumar*  
31/05/2022  
Chemist

Public Health Division, Biharsharif

Nalanda

*Chemist*

Public Health Division,  
Bihar Sharif (Nalanda)